

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
SAN FRANCISCO BAY REGION

ORDER NO. 77-104

CITY OF PACIFICA  
ORDER GRANTING ADDITIONAL DISCHARGES  
TO THE CITY'S SEWER SYSTEM PURSUANT  
TO ORDER NO. 76-101

I. FINDINGS

The California Regional Water Quality Control Board, San Francisco Bay Region, finds that:

- A. On December 6, 1974, this Board adopted Order No. 74-166, an NPDES Permit, prescribing waste discharge requirements for the discharge of the City of Pacifica.
- B. On September 21, 1976, this Board adopted Order No. 76-101, a cease and desist order, which prohibited additional discharges to the City's sewer system.
- C. Order No. 76-101 provided for partial removal of the prohibition and allowance of additional discharges to the sewer system upon forthwith achievement and completion of certain specified tasks or additional tasks not specified in the orders and which represent a measure of substantial progress.
- D. On October 19, 1976, November 16, 1976, April 19, 1977 and May 17, 1977, this Board adopted Order Nos. 76-112, 76-123, 77-33 and 77-52, respectively, granting a partial removal of the prohibition on additional discharges to the City's sewer system.
- E. The City has completed installation of permanent odor control facilities for the existing treatment units. These odor control facilities are operational and have eliminated the threat of future odor nuisance problems from existing facilities. This action represents a measure of substantial progress towards elimination of actual and threatened violations of waste discharge requirements.
- F. Compliance with other limitations of Order Nos. 74-166 and 76-101 has not deteriorated. Compliance with time schedules of Order No. 76-101 has deteriorated; however, this has not been the fault of the City.
- G. On July 19, 1977, the California Regional Water Quality Control Board, San Francisco Bay Region, after due notice, held a public hearing under provisions of Water Code Section 13301 regarding the discharge of waste and pollutants by the City of Pacifica.

II. IT IS HEREBY ORDERED THAT the prohibition of additional discharges to the sewer system as provided in Order No. 76-101 is partially removed and the City of Pacifica is allowed additional discharges to the sewer system sufficient to serve those proposed projects for which the City has received and processed all documents required by the City for issuance of a building permit prior to July 19, 1977.

I, Fred H. Dierker, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, San Francisco Bay Region, on July 19, 1977.

FRED H. DIERKER  
Executive Officer